

**City of Cocoa Beach – Reclaimed Water ASR**

**Table I**

<b>Cycle</b>	<b>Injection</b>		<b>Storage</b>	<b>Recovery</b>	
	<b>Duration (days)</b>	<b>Rate (gpm)</b>	<b>Duration (days)</b>	<b>Duration (days)</b>	<b>Rate (gpm)</b>
<b>1</b>	<b>15</b>	<b>1,400</b>	<b>7</b>	<b>*</b>	<b>1,000</b>
<b>2</b>	<b>30</b>	<b>1,400</b>	<b>28</b>	<b>*</b>	<b>1,000</b>
<b>3</b>	<b>45</b>	<b>1,400</b>	<b>60</b>	<b>*</b>	<b>1,000</b>

**Note – During injection and recovery water will flow 24 hours per day.**

**Note – “\*” Water will be recovered from the ASR well until reclaimed water standards are exceeded.**

**gpm - gallons per minute**